

Water Testing Laboratories of Maryland, Inc.

P.O. Box 4547, Salisbury, Maryland 21803

Phone 410-546-1318 Fax 410-546-5028 salisbury@wtlmd.com

Donald Burdick

Report #: S19985

Sample Identification: Drinking Water Refrigerated(<10°C): Yes
 Sampled by: 4252AG; Ashley Gizzi Delivered by: 4252AG; Ashley Gizzi
 Collected: 3/1/2022 9:55 AM Received: 3/1/2022 2:50 PM

Sample Address: 110 Crazy Horse Trail Millsboro, DE 19966
 Sample Source: front outside spigot
 Field Record: Chlorine residual: Absent Clear when drawn pH: 5.8

Analytical Results

Parameter	Result	Units	Reporting Limit	Date Analyzed	Method
PFOA	5.4	ppt	1.9	3/9/2022	537.1
PFOS	2.2	ppt	1.9	3/9/2022	537.1
PFBS	2.1	ppt	1.9	3/9/2022	537.1
PFHpA	2.0	ppt	1.9	3/9/2022	537.1
PFHxS	ND	ppt	1.9	3/9/2022	537.1
PFNA	ND	ppt	1.9	3/9/2022	537.1

ppt= parts per trillion
 ND= Not Detected

N/A= Not Applicable

***EPA Secondary Drinking Water Standard:** Non-enforceable guidelines regulating contaminants that cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste or odor) in drinking water.

****Standard for new wells:** See Code of Maryland Regulations (COMAR) 26.04.04.16E(5).

The EPA has not issued an enforceable federal drinking water standard for PFAS. They have, however, issued a health advisory limiting lifetime exposure to 70 ppt for PFAS and PFOS combined. The health advisory is not enforceable.

REPORTED BY: CARRIE MYERS

Water Testing Laboratories is a Water Quality Laboratory certified in Maryland, Delaware and Virginia.