

Subject: Fw: Delaware Energy Code Training Workgroup
Date: Monday, July 21, 2025 at 3:56:36 PM Eastern Daylight Time
From: Keating, Anna (DNREC)
To: Smith, Theresa L (DNREC)
Attachments: image.png, image.png, 2101 Regulations for Delaware Energy Conservation Code 2025-06-09T14_41_26.pdf

From: Brozyna, Kevin <KBrozyna@KHOV.COM>
Sent: Friday, July 11, 2025 8:00 AM
To: Brown, Amatullah (DNREC) <amatullah.brown@delaware.gov>; Keating, Anna (DNREC) <anna.e.keating@delaware.gov>
Cc: Noyes, Thomas G. (DNREC) <Thomas.Noyes@delaware.gov>
Subject: Re: Delaware Energy Code Training Workgroup

Good morning Amatullah

Thanks for the reply. We can take another look back, but measures like R408.2.1.4 Reduced air leakage with 2 points in climate zone 4 (except marine) from table 408 are not showing up in the table from the proposed 2101 regulation. Perhaps we're looking at an outdated version of the proposed regulation, but I've attached a copy of the version for reference. And below is the screen shot from 2024 IECC 408

TABLE R408.2 CREDITS FOR ADDITIONAL ENERGY EFFICIENCY						
MEASURE NUMBER	MEASURE DESCRIPTION	CREDIT VALUE				
		Climate Zones 0 & 1	Climate Zone 2	Climate Zone 3	Climate Zone 4 Except Marine	Climate Zone 4 Marine
R408.2.1.3(2)	Roof solar reflectance index (roof is above an unconditioned space that contains a duct system)	1	1	0	0	0
R408.2.1.4	Reduced air leakage	1	1	1	2	1
R408.2.2(1) ^b	Ground source heat pump	14	14	14	15	10
R408.2.2(2) ^b	High Performance Cooling (Option 1)	5	4	3	2	1
R408.2.2(3) ^b	High Performance Cooling (Option 2)	6	4	3	2	1

R408.2.2.1 also looked to be added, which is great to see a potential additional credit. However, just different from table 408.

Some of the additional formatting or changing the verbiage and adding footnotes into the body (with the likely intent to consolidate the info) just adds a bit of confusion for folks that are used to table 408 formatting from the '24 IECC.

Thanks