

MAIL TO:  
 WATER SUPPLY SECTION  
 DIVISION OF WATER  
 RESOURCES  
 89 KINGS HIGHWAY  
 DOVER, DELAWARE 19901

STATE OF DELAWARE  
 DEPARTMENT OF NATURAL RESOURCES  
 AND ENVIRONMENTAL CONTROL

http://www.dnrec.state.de.us/


APPLICATION MUST BE SUBMITTED  
 AND PERMIT RECEIVED BEFORE  
 DRILLING IS STARTED.

WELL COMPLETION REPORT

- OFFICIAL USE ONLY -

PHONE: 302-739-9944  
 FAX: 302-739-7764

PAGE # _____ OF _____ PAGES
PERMIT #: <b>261531</b>

<b>Owner:</b> Sandhill Real Estate Investments Llc	<b>LOCATION MAP - ROAD MAP</b>															
<b>Address:</b> 1681 Hudson Road Milton DE US 19968	<b>County:</b> Sussex															
<b>Telephone:</b> (302)345-4773	<b>Tax Parcel:</b> 1-35-10.00-0063.00															
<b>Email:</b> tony@sposatolandscap.com	<b>Lot #:</b>															
<b>Permit #:</b> 261531	<b>WELL HEAD COMPLETION</b>															
<b>Local ID:</b>	<b>Type:</b> Other															
<b>Licensed Preparer / WC:</b> A C Schultes Of Delaware	<b>Other:</b> 12" Cap															
<b>License #:</b> 14	<b>Well Head Completed:</b> 24.00 in. Above Ground Surface															
<b>Well Driller in Charge:</b>	Was the Well Tag attached in accordance with current regulations?															
<b>License #:</b> 5324	Yes															
<b>Construction Method:</b> Reverse Rotary	Comments:															
<b>Total Depth of Excavation:</b> 109.00 feet																
<b>Construction Date:</b> 5/4/2021																
<table border="1"> <thead> <tr> <th>Casing</th> <th>Top</th> <th>Bottom</th> <th>Diameter</th> <th>Material</th> </tr> </thead> <tbody> <tr> <td>Inner Casing</td> <td>2.00</td> <td>21.00</td> <td>24.00</td> <td>Steel</td> </tr> <tr> <td>Inner Casing</td> <td>1.00</td> <td>73.00</td> <td>12.00</td> <td>Steel</td> </tr> </tbody> </table>	Casing	Top	Bottom	Diameter	Material	Inner Casing	2.00	21.00	24.00	Steel	Inner Casing	1.00	73.00	12.00	Steel	
Casing	Top	Bottom	Diameter	Material												
Inner Casing	2.00	21.00	24.00	Steel												
Inner Casing	1.00	73.00	12.00	Steel												
<b>Screen Material:</b> Stainless Steel	<b>Diameter:</b> 12.00															
<b>Top:</b> 73.00	<b>Bottom:</b> 102.00															
<b>Type of Grout:</b> Bentonite/Cement Mixture																
<b>Top:</b> 0.00	<b>Bottom:</b> 60.00															
<b>Gravel Pack Interval:</b>																
<b>Top:</b> 60.00	<b>Bottom:</b> 109.00															
<b>Type of Non-Grout Backfill of Well Annulus:</b> None																
<b>Top:</b> 0.00	<b>Bottom:</b> 0.00															
<b>Screen Slot Size:</b> 0																
<b>Gravel Pack Size:</b> 3																
<b>Static Water Level:</b> 11.00 ft. Below Ground Surface																
<b>Date:</b> 5/19/2021	<b>X:</b> 205791.39															
<b>Pumping Water Level:</b> 37.0000 ft.	<b>Y:</b> 81356.09															
<b>Date:</b> 5/21/2021																
<b>After:</b> 48.00 hrs.																
<b>Pumping at:</b> 1,108.00 GPM																
<b>Was a Geophysical Log Taken?</b> Yes																
<b>Parcel Size:</b> Greater than 0.5 Acre																
<b>Proposed Well will be:</b>																
250.00 Feet of the FRONT property line																
250.00 Feet of the BACK property line																
450.00 Feet of the LEFT property line																
200.00 Feet of the RIGHT property line																
250.00 Feet from the NEAREST road																
0.00 Feet from the SEPTIC TANK and all components																
0.00 Feet from the SEPTIC DRAINFIELD/CESSPOOL																
200.00 Feet from the CENTRAL SEWER LINE																
I HEREBY AFFIRM THE INFORMATION I HAVE SUBMITTED IS ACCURATE AND CORRECT.																
<b>Signature - Licensed Preparer/Well Contractor</b>	<b>Date</b>															
<b>Signature - Property Owner</b>	<b>Date</b>															
																

MAIL TO:

WATER SUPPLY SECTION  
DIVISION OF WATER  
RESOURCES  
89 KINGS HIGHWAY  
DOVER, DELAWARE 19901

PHONE: 302-739-9944  
FAX: 302-739-7764

STATE OF DELAWARE  
DEPARTMENT OF NATURAL RESOURCES  
AND ENVIRONMENTAL CONTROL

<http://www.dnrec.state.de.us/>

APPLICATION MUST BE SUBMITTED  
AND PERMIT RECEIVED BEFORE  
DRILLING IS STARTED.

WELL COMPLETION REPORT

- OFFICIAL USE ONLY -

PAGE # \_\_\_\_ OF \_\_\_\_ PAGES

PERMIT #: \_\_\_\_\_

FORMATION LOG			
Formation Type:	Fine Sand	Other:	
Formation Type With:	Sand	Other:	
From:	0.00	To:	12.00
Color:	Brown		
Texture	Fine	Other:	
To:	Fine	Other:	
Cement:		Other:	
Sorting:		Other:	
Hardness:		Other:	
Comment:			
Formation Type:	Fine Sand	Other:	
Formation Type With:	Other	Other:	Gravel
From:	12.00	To:	67.00
Color:	White		
Texture	Fine	Other:	
To:	Fine	Other:	
Cement:		Other:	
Sorting:		Other:	
Hardness:		Other:	
Comment:			
Formation Type:	Fine Sand	Other:	to Coarse
Formation Type With:	Other	Other:	Gravel & Rocks
From:	67.00	To:	96.00
Color:	Tan		
Texture	Fine	Other:	
To:	Fine	Other:	
Cement:		Other:	
Sorting:		Other:	
Hardness:		Other:	
Comment:			
Formation Type:	Medium Sand	Other:	to Coarse
Formation Type With:	Other	Other:	Gravel, Rocks & Iron ore
From:	96.00	To:	105.00
Color:	Orange		
Texture	Medium	Other:	
To:	Medium	Other:	
Cement:		Other:	
Sorting:		Other:	
Hardness:		Other:	
Comment:			
Formation Type:	Fine Sand	Other:	Silty
Formation Type With:	Clay	Other:	
From:	105.00	To:	109.00
Color:	Gray		
Texture	Fine	Other:	
To:	Fine	Other:	
Cement:		Other:	
Sorting:		Other:	
Hardness:		Other:	

MAIL TO:

WATER SUPPLY SECTION  
DIVISION OF WATER  
RESOURCES  
89 KINGS HIGHWAY  
DOVER, DELAWARE 19901

PHONE: 302-739-9944  
FAX: 302-739-7764

**STATE OF DELAWARE  
DEPARTMENT OF NATURAL RESOURCES  
AND ENVIRONMENTAL CONTROL**

**WELL COMPLETION REPORT**

<http://www.dnrec.state.de.us/>

**APPLICATION MUST BE SUBMITTED  
AND PERMIT RECEIVED BEFORE  
DRILLING IS STARTED.**

**- OFFICIAL USE ONLY -**

**PAGE # \_\_\_\_\_ OF \_\_\_\_\_ PAGES**

**PERMIT #: \_\_\_\_\_**

**Comment:**