

MAIL TO:

WATER SUPPLY SECTION
DIVISION OF WATER
RESOURCES
89 KINGS HIGHWAY
DOVER, DELAWARE 19901

PHONE: 302-739-9944
FAX: 302-739-7764



DELAWARE DEPARTMENT OF
NATURAL RESOURCES AND
ENVIRONMENTAL CONTROL

<https://www.dnrec.state.de.us/>

APPLICATION MUST BE SUBMITTED
AND PERMIT RECEIVED BEFORE
DRILLING IS STARTED.

APPLICATION FOR A PERMIT TO CONSTRUCT A WELL

- OFFICIAL USE ONLY -

PAGE # OF PAGES

PERMIT #: **286696**

Owner: White Marlin Llc	LOCATION MAP - ROAD MAP
Address: 30618 DuPont Boulevard Dagsboro DE US 19939	County: Sussex
Telephone: (302)381-5591	Tax Parcel: 5-33-11.00-0017.00
Email:	Lot #:
Licensed Preparer / WC: Daiseys Well Drilling	Subdivision:
License #: 13	ADC Map Grid:
Estimated Construction Date: 9/13/2024	Name of Nearest Town: Roxana
	Distance to Nearest Town: 0.50
Purpose: Permanent	X: 222329.22
Use: Public Standard	Y: 54083.73
Use Other:	
Is an Emergency well? No	
Is a Replacement well? Yes	
Reason: Relocating	
Is public water available? No	
Utility:	
On public sewage? No	
Septic Permit #: Existing	
PROPOSED WELL CONSTRUCTION:	
Approximate Total Depth: 90.00 feet 180' MGD	
Maximum capacity: 20.00 (GPM)	
Max. Daily Withdrawal: 800.00 (GPD)	
Casing	Parcel Size: Greater than 0.5 Acre
Inner Casing Top: 0.00 Bottom: 80.00 180' Diameter: 4.00 Material: PVC	Proposed Well will be:
Screen Material: PVC	55.00 33' Feet of the FRONT property line
Top: 80.00 160' Bottom: 90.00 180' MGD	195.00 217' Feet of the BACK property line
Type of Grout: Bentonite	22.00 109' Feet of the LEFT property line
Top: 0.00 Bottom: 55.00 155' MGD	102.00 87' Feet of the RIGHT property line
Gravel Pack Interval:	55.00 33' Feet from the NEAREST road
Top: 65.00 155' Bottom: 80.00 180' MGD	160.00 210' Feet from the SEPTIC TANK and all components
Type of Non-Grout Backfill of Well Annulus: None	170.00 105' Feet from the SEPTIC DRAINFIELD/CESSPOOL
Top: 0.00 Bottom: 0.00	0.00 Feet from the CENTRAL SEWER LINE
Will the operation of this well by itself or in combination with any other well(s), owned or operated by the permittee, withdraw greater than 1,000,000 gallons in any 24hr. period? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Made changes 9-10-24

Ref#: 76944