



Department of Natural Resources and Environmental Control
 Division of Water
 89 Kings Hwy
 Dover, DE 19901
 Ph: 302-739-9944
 Fax: 302-739-7764
www.dnrec.delaware.gov

REQUEST FOR ALTERNATIVE METHOD OF COMPLIANCE

I, SEAWINDS POA owner of property located on 32341 Falling Point Rd. Dagsboro, DE. 19939
 tax map identification # 1-34-6.00-157.00 formally request an Alternative Method of
 Compliance of Section 12.0 of the Delaware Regulations Governing the Construction and Use of Wells.

Subsection 5.1.1.1 of the Delaware Regulations Governing the Construction and Use of Wells states in
 relevant part: "Public wells shall have a minimum separation distance of 150 feet except as addressed in
 subsections 5.1.1.5, 5.1.1.6 and 5.1.1.7.

The physical size of parcel # 1-34-6.00-157.00 prohibits the required isolation distance of
 one hundred fifty (150) feet from the Proposed well to the Existing septic components.

A good faith effort has proven the *maximum* isolation distance to be 140'.

Attached is a plot plan of the parcel and a check in the amount one hundred (\$100.00) dollars made
 payable to the DNREC, State of Delaware allowing the Alternative Method of Compliance to be
 advertised in newspapers of local and statewide circulation with a comment period of fifteen (15) days. A
 public hearing will be held if a meritorious request is received within the fifteen (15) day period.

I, BRIAN BWARD, PRESIDENT hereby affirm this application and any plans reports, or documents
 submitted with this application to be true and correct to the best of my knowledge and belief.

Property Owners Signature

[Signature] Date 8-30-24

SWORN TO AND SUBSCRIBED before me the 30th day of AUGUST, A.D., 2024.

JOHN CHARLES PAPUCHIS
 NOTARY PUBLIC
 STATE OF DELAWARE
 My Commission Expires February 10, 2026

[Signature]
 NOTARY PUBLIC

GLB

V-10468
P0240 10754