



414 High Street | PO BOX 1100
Seaford, DE 19973
302.629.9173
302.629.9307 fax
www.seafordde.com

June 4, 2025

Jonathan D. Richard, P.E.
309 South Governors Avenue
Dover, Delaware 19904

REF: Bridgeville Warehouses
Parcel #131-19.00-4.00
CAPACITY AVAILABILITY

Dear Mr. Richard,

We are providing this response regarding the construction of the Bridgeville Warehouses located at the above referenced parcel number. They are proposing to connect to Sussex County's force main which ultimately flows to Seaford's wastewater treatment facility. The project is approximately 43 Equivalent Dwelling Units (EDU). Based on 250 gallons per day (gpd) / per EDU the project would require 10,750 GPD with a peak flow of 37,625 GPD. The City of Seaford has sufficient capacity to treat and dispose of this additional flow at our Seaford Wastewater Facility. The NPDES permit for City of Seaford is DE0020265.

If you have questions or need additional information, please do not hesitate to contact me at 302-629-8307.

Sincerely,

City of Seaford

Berley Mears
Director of Public Works

Cc: Charles Anderson, CM
Bryant Tift, WWOC
Mike Bailey, BO
Chris Derbyshire, P.E.