



Department of Natural Resources and Environmental Control  
Division of Water  
89 Kings Hwy  
Dover, DE 19901  
Ph: 302-739-9944  
Fax: 302-739-7764  
[www.dnrec.delaware.gov](http://www.dnrec.delaware.gov)

## REQUEST FOR ALTERNATIVE METHOD OF COMPLIANCE

I, David King owner of property located on 955 Bay Rd., Milford, DE 19963 tax map identification # 5-00-163.14-01-37.00 / 000 formally request an Alternative Method of Compliance of Section 12.0 of the Delaware Regulations Governing the Construction and Use of Wells.

Subsection 5.1.1.1 of the Delaware Regulations Governing the Construction and Use of Wells states in relevant part: "Public wells shall have a minimum separation distance of 150 feet except as addressed in subsections 5.1.1.5, 5.1.1.6 and 5.1.1.7.

The physical size of parcel # 5-00-163.14-01-37.00 / 000 prohibits the required isolation distance of one hundred fifty (150) feet from the proposed well to the existing septic tank.

A good faith effort has proven the *maximum* isolation distance to be 125'.

Attached is a plot plan of the parcel and a check in the amount one hundred (\$100.00) dollars made payable to the DNREC, State of Delaware allowing the Alternative Method of Compliance to be advertised in newspapers of local and statewide circulation with a comment period of fifteen (15) days. A public hearing will be held if a meritorious request is received within the fifteen (15) day period.

I, David King hereby affirm this application and any plans reports, or documents submitted with this application to be true and correct to the best of my knowledge and belief.

Property Owners Signature

David P. King Date 10/2/25  
SWORD TO AND SUBSCRIBED before me the 2 day of October, A.D., 2025.



Christy L. Bakas

NOTARY PUBLIC