

Facility Name:

Department Of Natural Resources and Environmental Control Tanks Compliance Branch 391 Lukens Drive New Castle, DE 19720 (302)395-2500 (phone)

DNRECTanksCompliance@delaware.gov

https://dnrec.alpha.delaware.gov/waste-hazardous/tanks/

Monthly Stage I EVR Inspection All routine inspection records must be kept for a minimum of Five (5) years.

Facility ID #:

Date	Fill Adapter & Caps	Stage I Dry Breaks & Cap	ATG Cap	Vent P/V Valve

The Department of Natural Resources and Environmental Control, Tank Compliance Branch (DNREC-TCB) has developed this guidance sheet to assist tank owners, operators and contractors in complying with the 1124 Control of Volatile Organic Compound Emissions (VR Regulations), Sections 36.6.1. and Sections 36.6.2.

Owners and operators must conduct an inspection once every 28 to 31 calendar days to monitor the condition of all Caps, Fill Adapters, Stage I Dry Break, and Vent P/V valve. The routine inspection shall at a minimum include the following:

Manually check all dust caps for tightness. Check fill and Stage I swivel adapters to ensure they are tightly positioned. Check and ensure the jackscrew assembly is tight.

Manually check Stage I dry breaks to ensure they are tightly sealed. Check all dry break caps manually for tightness.

Manually check the automatic tank gauge (ATG) caps to ensure they are tightly sealed and that the associated electrical grommets and vent extractor caps are in good working condition.

Visually inspect the vent riser, P/V valve and cap for damage visible from the ground level

If a problem was noted during the Routine Walk-Around Inspection, document all problems & measures to correct the problem on the next page of this form.

If at any time during a routine inspection evidence of a release of regulated substance is discovered owners and operators must contact the Tank Compliance Branch at (302) 395-2500.

Problems Identified During Routine Walk-Around Inspection

Date	Equipment w/ Problem	Corrective Measures Taken