



STATE OF DELAWARE  
DEPARTMENT OF NATURAL RESOURCES  
& ENVIRONMENTAL CONTROL  
DIVISION OF WATER RESOURCES  
20653 DUPONT BLVD  
UNIT 5  
GEORGETOWN, DE 19947

November 13, 2000

Mr. Dick Bachelder  
PSA, Inc.  
P.O. Box 218902  
Columbus, OH, 43221

RE: BioDiffuser Standard Model Plastic Leaching Chamber Approval

Dear Mr. Bachelder

The Division of Water Resources is pleased to inform you that we are able to approve the Standard Model BioDiffuser plastic leaching chamber, for use in accordance with all accepted and approved Departmental policies and procedures regarding the use of gravelless chambers in on-site wastewater treatment and disposal systems in Delaware. This includes the ability to take a 25% reduction in the required drainfield area.

In the case of one of the previously approved gravelless chambers, a 40% reduction was allowed. This reduction is currently under review, by the Department and may at some point be rescinded; however if this does not occur your product will surly be considered for the additional reduction.

Please feel free to contact the Ground Water Discharges Section if you have any questions at 1-302-739-4761

Sincerely,

Rodney L. Wyatt  
Program Manager I I  
Ground Water Discharges Section

*Delaware's good nature depends on you!*