



Department of Natural Resources and Environmental Control  
Division of Water  
89 Kings Hwy  
Dover, DE 19901  
Ph: 302-739-9944  
Fax: 302-739-7764  
[www.dnrec.delaware.gov](http://www.dnrec.delaware.gov)

## REQUEST FOR ALTERNATIVE METHOD OF COMPLIANCE

I, \_\_\_\_\_ owner of property located on \_\_\_\_\_  
tax map identification # \_\_\_\_\_ formally request an Alternative Method of  
Compliance of Section 12.0 of the Delaware Regulations Governing the Construction and Use of Wells.

Subsection 5.1.1.1 of the Delaware Regulations Governing the Construction and Use of Wells states in  
relevant part: "*Public wells shall have a minimum separation distance of 150 feet except as addressed in  
subsections 5.1.1.5, 5.1.1.6 and 5.1.1.7.*"

The physical size of parcel # \_\_\_\_\_ prohibits the required isolation distance of  
one hundred fifty (150) feet from the \_\_\_\_\_ well to the \_\_\_\_\_ septic \_\_\_\_\_.

A good faith effort has proven the *maximum* isolation distance to be \_\_\_\_\_.

Attached is a plot plan of the parcel and a check in the amount one hundred (\$100.00) dollars made  
payable to the DNREC, State of Delaware allowing the Alternative Method of Compliance to be  
advertised in newspapers of local and statewide circulation with a comment period of fifteen (15) days. A  
public hearing will be held if a meritorious request is received within the fifteen (15) day period.

I, \_\_\_\_\_ hereby affirm this application and any plans reports, or documents  
submitted with this application to be true and correct to the best of my knowledge and belief.

Property Owners Signature

\_\_\_\_\_ Date \_\_\_\_\_

SWORD TO AND SUBSCRIBED before me the \_\_\_\_ day of \_\_\_\_\_, A.D., \_\_\_\_\_.

---

NOTARY PUBLIC